

**Chapter 15.28****WASTE WATER SYSTEM**

(2491-7/81, 3037-5/90)

**Sections:**

- 15.28.010 Waste Water System
- 15.28.020 Sewer Connection Permit--Application Fee
- 15.28.030 Contents of Application--Property Description
- 15.28.040 Damages
- 15.28.050 Discharge Line
- 15.28.060 Rules for Laying Drainpipe to Sanitary Sewer

**15.28.010 Waste Water System.** For the purpose of handling industrial wastes from oil and gas wells, including waste water and brine, the Public Works Department shall issue a sewer connection permit whenever such waste is to be deposited into the City's sanitary sewer system, provided such industrial waste does not contain more than one hundred (100) milligrams/liter of any crude, distilled or refined petroleum products, mud, rotary mud, oils, or other residual products mentioned in Orange County Sanitation District discharge regulations. Such industrial waste shall be processed through a clarification system approved by the Fire Department. At no time shall discharge water be over 140° fahrenheit at point of entry to the sewer. Violations of this section shall constitute a misdemeanor punishable as set forth in Chapter 1.16 of the Huntington Beach Municipal Code. (2491-7/81, 3037-5/90)

**15.28.020 Sewer Connection Permit--Application Fee.** No connection shall be made to the City's sanitary sewer system until a sewer connection permit has been obtained from the public works Fire Department. An application for such sewer connection permit shall be filed with the Fire Department together with a fee per sewer connection, as established by resolution of the City Council. (2491-7/81)

**15.28.030 Contents of Application--Property Description.** Said application shall contain a description of the property upon which said water or waste water is located, the name of the owner of the property, the point where the water will be discharged into said sanitary sewer, the location of the clarifying plant, type of plant to be used, including plans and specifications approved by the Public Works Department and the method of clarifying and settling the objectionable substances from said water, including plans and specifications of waste water settling systems. (2491-7/81)

**15.28.040 Damages.** The permittee shall be responsible for all damages to City property. (2491-7/81)

**15.28.050 Discharge Line.** The discharge line shall have an approved gate valve and shall be provided with an approved method of observing or testing the waste water for impurities. (2491-7/81).

**15.28.060 Rules for Laying Drainpipe to Sanitary Sewer.** The method of installation for the discharge line from the clarifying tank, including all pipe and fittings, shall be in accordance with the provisions of the Huntington Beach Plumbing Code. No sewer connection to the City's sanitary sewer system shall be made by other than a licensed plumbing contractor. (2491-7/81)